

## Environmental Protection Agency

§ 60.30b

MWC plant capacity	Guidelines emission level (percent reduction or parts per million by volume)	
	SO <sub>2</sub>	HCl
Very large .....	70% or 30 ppmv .....	90% or 25 ppmv.
Large .....	50% or 30 ppmv .....	50% or 25 ppmv.

NOTE: All ppmv levels corrected to 7 percent O<sub>2</sub>. SO<sub>2</sub> emission levels and percent reductions are 24-hour geometric means.

Either the applicable percent reduction or the parts per million by volume guideline, whichever is less stringent, is the guideline limit for a designated facility.

### § 60.36a Emission guidelines for municipal waste combustor operating practices, training, and municipal waste combustor operator certification.

(a) For approval, a State plan shall include the emission guidelines for carbon monoxide listed below, except as provided for under § 60.24. The emission guidelines for the carbon monoxide concentration level for each designated facility located within a large or very large MWC plant are shown in Table 1.

TABLE 1.—MWC OPERATING GUIDELINES

MWC technology	Carbon monoxide emission level (parts per million by volume) <sup>1</sup>	Averaging time
Mass burn waterwall .....	100	4 hour.
Mass burn refractory .....	100	4 hour.
Mass burn rotary waterwall .....	250	24 hour.
Modular starved air .....	50	4 hour.
Modular excess air .....	50	4 hour.
Refuse derived fuel stoker .....	200	24 hour.
Bubbling fluidized bed combustor.	100	4 hour.
Circulating fluidized bed combustor.	100	4 hour.
Coal/RDF mixed fuel-fired combustors.	150	4 hour.

<sup>1</sup> Measured at the combustor outlet in conjunction with a measurement of oxygen concentration, corrected to 7 percent oxygen (dry basis). Calculated as an arithmetic average.

(b) For approval, a State plan shall include the requirements for MWC operating practices, operator certification and training listed in § 60.56a of subpart Ea, except as provided for under § 60.24.

### § 60.37a [Reserved]

### § 60.38a Compliance and performance testing and compliance times.

(a) For approval, a State plan shall include, for designated facilities located within large and very large MWC plants, the compliance and performance testing methods listed in § 60.58a of subpart Ea for large MWC plants, as applicable, except as provided for under § 60.24. The compliance methods under § 60.58a for nitrogen oxide are not applicable to designated facilities located within large or very large MWC plants.

(b) [Reserved]

(c) Except as provided for under paragraph (d) of this section, planning, awarding of contracts, and installation of equipment capable of attaining the level of the emission guidelines established under this subpart are expected to be accomplished within 36 months after the effective date of State emission standards for MWC units.

(d) [Reserved]

### § 60.39a Reporting and recordkeeping guidelines.

For approval, a State plan shall include the reporting and recordkeeping provisions listed in § 60.59a, as applicable, except as provided for under § 60.24.

### Subpart Cb—Emissions Guidelines and Compliance Schedules for Municipal Waste Combustors

SOURCE: 60 FR 65415, Dec. 19, 1995, unless otherwise noted.

### § 60.30b Scope.

This subpart contains emission guidelines and compliance schedules for the control of certain designated pollutants from certain municipal waste combustors in accordance with section 111(d) and section 129 of the Clean Air Act and subpart B of this part. The provisions in these emission guidelines supersede the provisions of § 60.24(f) of subpart B of this part.